



Town of Billerica

Audit Report

- Audit Complete
- Town Boundary

Street Light Audit Summary for September 23 - 27, 2019

Total Fixtures (Approx):	2,603	Remaining Fixtures:	1,500
Fixtures Audited:	1,103	Percent Complete:	42%



Town of Billerica

LED Street Light Conversion: Audit Phase
 Reported Issues: September 23 - 27, 2019



POLE NUMBER	ISSUE REPORTED	AUDIT DATE	APPROXIMATE ADDRESS	COORDINATES
4	Damaged Fixture	9/23/2019	11 Elizabeth Rd	42.533697, -71.250803
3	Damaged Fixture	9/23/2019	58 Cynthia Rd	42.531062, -71.245512
265	Damaged Fixture	9/23/2019	653 Boston Rd	42.539758, -71.246025
9	Damaged Fixture	9/24/2019	20 Pinedale Ave	42.528386, -71.223103
X	Damaged Fixture	9/24/2019	102 Summit Rd	42.529159, -71.219127
21	Damaged Fixture	9/25/2019	45 Riverdale Rd	42.543467, -71.233464
2	Damaged Fixture	9/25/2019	6 Marshbrook Rd	42.539290, -71.239953
8	Damaged Fixture	9/25/2019	4 Monroe Way	42.539262, -71.218869
247	Damaged Fixture	9/25/2019	65 Connolly St	42.539715, -71.209326
025068	Damaged Fixture	9/27/2019	1 River St	42.560451, -71.269553
2	Damaged Fixture	9/27/2019	99 Aberdeen St	42.544024, -71.225707
549	Damaged Fixture, Major Tree Issue (blocks install)	9/24/2019	69 Dorsett Ave	42.530692, -71.227567
27	Damaged Pole	9/23/2019	56 Wyman Rd	42.535031, -71.250439
580	Damaged Pole	9/23/2019	17 Adelman Rd	42.524495, -71.224714
X	Damaged Pole	9/25/2019	41 Middlesex Tpke	42.512165, -71.233045
X	Damaged Pole	9/25/2019	35 Middlesex Tpke	42.512255, -71.234483
X	Damaged Pole	9/25/2019	37 Middlesex Tpke	42.512138, -71.234729
X	Damaged Pole	9/25/2019	25 Middlesex Tpke	42.511759, -71.235008
X	Damaged Pole	9/25/2019	25 Middlesex Tpke	42.511550, -71.235053

Town of Billerica

LED Street Light Conversion: Audit Phase
 Reported Issues: September 23 - 27, 2019



POLE NUMBER	ISSUE REPORTED	AUDIT DATE	APPROXIMATE ADDRESS	COORDINATES
57	Damaged Pole	9/25/2019	9 Scroxtton Dr	42.537311, -71.240949
27	Damaged Pole	9/23/2019	53 Shawsheen Rd	42.527500, -71.238394
1	Day Burner	9/23/2019	2 Putnam Rd	42.534119, -71.239075
5	Day Burner	9/25/2019	46 Wentworth Dr	42.548695, -71.245315
X50	Day Burner	9/25/2019	62 Pinehurst Ave	42.532333, -71.219649
13	Day Burner	9/27/2019	38 Sachem St	42.545436, -71.228814
X	Day Burner, Major Tree Issue (blocks install)	9/24/2019	5 Allendale Ave	42.533860, -71.229296
X	Hand Hole Cover Missing or Damaged	9/27/2019	437 Boston Rd	42.555620, -71.266375
3	Major Tree Issue (blocks install)	9/24/2019	23 A St	42.529334, -71.230067
1	Major Tree Issue (blocks install)	9/24/2019	7 B St	42.528679, -71.230724
X	Pole Rusted	9/24/2019	4 Middlesex Tpke	42.512030, -71.232727
	Double Wood Pole		This Reporting Period: 14	Cumulative Total: 22